

CLASS 125 CAST BRONZE, GATE VALVES

KITZ Fig: AK125M

Sizes: 1/2-3inch(15-80mm)

SCREWED BONNET, INSIDE SCREW, AND SCREWED ENDS.

Standards

- End to End: KITZ STANDARD
- End Connection: ASME B1.20.1
- Wall Thickness: KITZ STANDARD

Test Standard

- KITZ STANDARD

Dimensions

SIZE (inch/mm)	L	L1	H	D1	Kg
1/2 15	51.0	0.0	129.0	55.0	0.00
3/4 20	56.0	0.0	155.0	60.0	0.00
1 25	66.0	0.0	180.0	70.0	0.00
1 1/4 32	68.0	0.0	216.0	80.0	0.00
1 1/2 40	74.0	0.0	257.0	90.0	0.00
2 50	84.0	0.0	296.0	100.0	0.00
2 1/2 65	115.0	0.0	371.0	135.0	0.00
3 80	130.0	0.0	432.0	155.0	0.00


Material List

NAME OF PART	MATERIAL	SPECIFICATION
BODY	CAST BRONZE	B62
BONNET	CAST BRONZE	B62
STEM	CAST BRONZE	B62
DISC	CAST BRONZE	B62

Specifications

CLASS 125 CAST BRONZE, GATE VALVES, SCREWED BONNET, INSIDE SCREW, AND SCREWED ENDS.

End to End : KITZ STANDARD, End Connection : ASME B1.20.1, Wall Thickness : KITZ STANDARD, Test Standard : KITZ STANDARD, Sizes : 1/2-3inch(15-80mm), BODY MATERIAL : CAST BRONZE, BONNET MATERIAL : CAST BRONZE, STEM MATERIAL : CAST BRONZE, DISC MATERIAL : CAST BRONZE, KITZ Fig : AK125M



For more details, please refer to the drawing.

Pressure-temperature ratings and other performance data published in this catalog have been developed from our design calculation, in-house testing, field reports provided by our customers and/or published official standards or specifications. They are good only to cover typical applications as a general guideline to users of Kitz products introduced in this catalog. For any specific application, users are kindly requested to contact Kitz Corporation for technical advice, or to carry out their own study and evaluation for proving suitability of these products to such an application. Failure to follow this request could result in property damage and/or personal injury, for which we shall not be liable. Read instruction manual carefully before use.

KITZ

KITZ CORPORATION 1-10-1 Nakase, Mihama-ku, Chiba 261-8577, Japan
© Kitz Corporation. All Right Reserved.

ISO 9001
CERTIFIED
Since 1989